

Risk assessment – Marden Playing Field Changing Rooms

All employers must conduct a risk assessment. If you have fewer than five employees you don't have to write anything down.

Company name: **MARDEN PARISH COUNCIL**

Date of risk assessment: **February 2023**

MARDEN PLAYING FIELD CHANGING ROOMS

Currently not in use

What are the hazards?	Who might be harmed and how?	What are you already doing?	Controls	Action by who?	Action by when?
Water contamination	Users of changing rooms	Regular inspection of shower heads: soaking in detergent during summer months Legionnaires checks	Water currently turned off and system drained down Continue regular inspections	Caretakers	Ongoing
Scalding (showers/taps)	Users of changing rooms	Ensure water is kept to the required temperature.	Water currently turned off and system drained down Any problems to be reported to the Parish Office for a plumber to be instructed to take out any work.	Caretakers	Ongoing
Electric shocks	Users of changing rooms	No loose electric cables All switches should be secured to the wall Any defects should be reported to the Parish Office	Regular monitoring Regular electrical testing undertaken	Caretakers	Ongoing
Trips and Falls	Users of changing rooms		Keep footways clear	Football Club Clerk	Ongoing
General		Building is regularly inspected by the caretaker Open Spaces Sub-Committee undertake a visual check every six months. Repairs are dealt with asap after reporting.			