West Moors Memorial Hall & Social Club
Station Road
West Moors
Ferndown
Dorset
BH22 0HZ

Inspection Date: 03/05/2023

t: +44 (0)1202 84 96 95
e: safe@thefirepoint.co.uk
w: thefirepoint.co.uk
m: Unit 3 Old Manor Farm Buildings
187 Leigh Road
Wimborne
Dorset
BH21 2BT

The Firepoint
Trusted Fire Safety
Services | Supplies | Support

Duration Test:

Emergency Lighting Inspection Report

Area	Device type	Function	Status	Comments
Hall Entrance	Bulkhead	180	Passed	
Ladies W/C	Bulkhead	180	Passed	
Gents W/C	Bulkhead	180	Passed	
Hall	Bulkhead	180	Passed	
Hall	Twinspot	180	Passed	
Hall	Bulkhead	180	Passed	
Hall	Twinspot	180	Passed	
Hall	Bulkhead	180	Passed	
Hall	Twinspot	180	Passed	
Stage	Bulkhead	180	Passed	
Small Meeting Room	Bulkhead	180	Passed	
Stage Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
W/C Circulation Space	Ceiling Mount	180	Passed	
Side Fire Exit	Bulkhead	180	Passed	
Kitchen	Bulkhead	180	Passed	
Social Club Fire Exit 1	Signbox	180	Passed	Observed dim
Social Club Fire Exit 2	Signbox	180	Passed	Observed dim
Social Club Pool Table	Bulkhead	180	Passed	
Social Club Office	Bulkhead	180	Passed	
Social Club Bar	Bulkhead	180	Passed	
Social Club Bar	Bulkhead	180	Passed	

European certification group ec ISO 9001 REGISTERED FIRM
UKAS MANAGEMENT SYSTEMS 054
IFEDA
BAFE BS 5306 Part 3 Portable Extinguisher Maintenance
BUY WITH CONFIDENCE
FIVE 5 YEAR WARRANTY Extinguisher Supplies

Quality Assured Fire Protection.

West Moors Memorial Hall & Social Club
Station Road
West Moors
Ferndown
Dorset
BH22 0HZ

Inspection Date: 03/05/2023

t: +44 (0)1202 84 96 95
e: safe@thefirepoint.co.uk
w: thefirepoint.co.uk
m: Unit 3 Old Manor Farm Buildings
187 Leigh Road
Wimborne
Dorset
BH21 2BT

The Firepoint

Trusted Fire Safety
Services | Supplies | Support