

Site Location	RUSPER SPORTS PAVILION
Building	
Date	01-07-26.

Hot and Cold Water Outlets

Location	Sentinel Outlet Yes/No	Incoming water main °C	Cold water stored Temp °C	Hot Water Temp °C	Pre TMV Hot °C	Pre TMV Cold °C	Mixed °C	Compliant Yes/No
Kitchen Tap	N	20.1	/	54.1				
H/W Basin	N	20.2	/	52.3				
REF Basin	N	20.1	/	39.1				
REF Shower	N	20.3	/	41.6				
Home Shower	N	20	/	48.1				

Signature

Date